

	TECHNICAL SPECIFICATION		No. I-ET-3010.00-5529-812-PAZ-001							
	CLIENT: DENGGE/ DE&P								SHEET 1 of 19	
	JOB:								-	
	AREA:								-	
SUB/ ES/ CIT	TITLE: ANNULUS PRESSURE MONITORING AND RELIEF SYSTEM								NP-1	
									SUB/ ES/ CIT	
INDEX OF REVISIONS										
REV.	DESCRIPTION AND/OR REVISED SHEETS									
0	ORIGINAL									
A	GENERAL REVISION AND CHANGES IN 4.9 (MATERIAL SELECTION)									
B	P&ID REVISION (PSV DISCHARGE) AND SET POINTS UPDATE									
C	PSV SET POINT REVISION AND INCLUSION OF ITEM 4.11 (PURGE)									
D	GENERAL REVISION AND CHANGES IN 6 (CONTINUOUS VENTED TYPE)									
E	NEW ALTERNATIVES FOR LOCAL DISCHARGE FOR TURRET AND SPREAD MOORING SYSTEM (CONTINUOUS VENTED TYPE)									
F	GENERAL REVISION									
G	GENERAL REVISION: DEFINITIONS (NPT, PI and PAH); Reference 5, TABLE 5.1; FIGURE 6.2; ITEM 7 (System Set Points); ITEM 3.1.12, 3.1.17, 4.3.17, 4.3.18, 5.3.14, 5.3.15, 6.1.2.17, 6.1.2.18, 6.2.2.2, 6.2.2.16, 6.2.2.17 and 6.2.2.21 for example									
H	Change the term "CONTRACTOR" to "CONTRACTOR/SELLER" (new definition in item 1) and – in the header of the document – "SUB/ES/DCT" to "SUB/ES/CIT" and "E&P" to "DENGGE/ DE&P" (client). ITEM 4.3.2, 4.3.16 and 6.1.2.11. Adjusts on the title of items 6.1.2 and 6.2.2									
	REV. 0	REV. A	REV. B	REV. C	REV. D	REV. E	REV. F	REV. G	REV. H	
DATE	16/10/2009	04/05/2011	03/01/2012	31/07/2013	25/09/2014	21/11/2014	31/10/2018	22/04/2021	19/07/2024	
DESIGN	E&P-ENGP	E&P-ENGP	E&P-ENGP	E&P-ENGP	E&P-CORP	E&P-CORP	SUB - LMS	SUB	SUB/ES	
EXECUTION	E. SIMÕES	W. CARRARA	E. SIMÕES	LOBIANCO	LOBIANCO	BXI5 – RF0Q	K058	K058	K058	
CHECK	LOBIANCO	E. SIMÕES	W. CARRARA	E. SIMÕES	PAULO	CARPIGIANI	BH6W	BERP	DVIB	
APPROVAL	C. PAULO	A. FRANÇA	LOBIANCO	A. FRANÇA	A. FRANÇA	A. FRANÇA	CXAX	CL29	CL29	
THIS DOCUMENT IS PROPERTY OF PETROBRAS, BEING PROHIBITED OUTSIDE OF THEIR PURPOSE										
FORM OWNED TO PETROBRAS N-0381 REV. L										

	TECHNICAL SPECIFICATION	No. I-ET-3010.00-5529-812-PAZ-001	REV. H
			SHEET 2 of 19
	TITLE: ANNULUS PRESSURE MONITORING AND RELIEF SYSTEM		NP-1 SUB/ ES/ CIT

INDEX

1. TERMS, ABBREVIATIONS AND DEFINITIONS.....	3
2. STANDARDS AND APPLICABLE DOCUMENTS	4
3. INTRODUCTION	4
3.1. GENERAL REQUIREMENTS	
4. AUTOMATIC TYPE.....	7
4.1. AUTOMATIC TYPE DESCRIPTION	
4.2. AUTOMATIC TYPE CONFIGURATION AND DATA LIST OF COMPONENTS	
4.3. COMPONENT BASIC REQUIREMENTS AND SPECIFICATIONS - AUTOMATIC TYPE	
5. NON-AUTOMATIC OR MANUAL TYPE	10
5.1. MANUAL TYPE DESCRIPTION	
5.2. MANUAL TYPE CONFIGURATION AND DATA LIST OF COMPONENTS	
5.3. COMPONENT BASIC REQUIREMENTS AND SPECIFICATIONS - MANUAL TYPE	
6. CONTINUOUS VENTED TYPE.....	12
6.1. CONTINUOUS VENTED TYPE (WITH HEADER)	
6.2. LOCAL CONTINUOUS VENTED TYPE	
7. SYSTEM SET POINTS.....	18
8. SYSTEM ACCEPTANCE TEST	19
9. DOCUMENTATION.....	19

 PETROBRAS	TECHNICAL SPECIFICATION	No.	I-ET-3010.00-5529-812-PAZ-001	REV.	H
				SHEET	3 of 19
	TITLE: ANNULUS PRESSURE MONITORING AND RELIEF SYSTEM			NP-1	
				SUB/ ES/ CIT	

1. TERMS, ABBREVIATIONS AND DEFINITIONS

Annulus – Space between two extruded polymer layers, for example, the internal pressure sheath and external sheath that is sealed in the end fitting (NOTE Permeated gas and liquid are generally free to move and mix in the annulus) – As per API SPECIFICATION 17J: 2014 (item 3.1.2).

CONTRACTOR/SELLER – The entity that is responsible for the Engineering, Procurement, and Construction of the Floating Production Unit (FPU), as established in the contract of the FPU.

Digital Transmitter – Microprocessor based instrument, with digital communication interface.

End Fitting – Structural/mechanical device for terminating the different pipe layers in such a way as to transfer the load between the flexible pipe and the connector and seal all internal and external fluid containment layers – As per API SPECIFICATION 17J: 2014 (item 3.1.28).

Flexible riser – A flexible pipe connecting a platform/buoy/ship to a flowline, seafloor installation, or another platform where the riser may be freely suspended (free, catenary), restrained to some extent (buoys, chains), totally restrained, or enclosed in a tube (I- or J-tubes) layers – As per API SPECIFICATION 17J: 2014 (item 3.1.38).

FMRC – Factory Mutual Research Corporation.

FPU – Floating Production Unit.

HV – Tag for manual blocking valve.

Internal Pressure Sheath – Polymer layer excluding any sacrificial layers that ensures internal-fluid integrity. This layer may consist of a number of sublayers, excluding sacrificial layers – As per API SPECIFICATION 17J: 2014 (item 3.1.42).

Maximum Measurement Error – Is the maximum error of the equipment, considering accuracy, linearity, hysteresis, repeatability and offset.

NPT – American National Standard Taper Pipe Thread.

Outer Sheath – Polymer layer used to protect the pipe against penetration of seawater and other external environments, corrosion, abrasion, and mechanical damage. This layer may consist of a number of sublayers – As per API SPECIFICATION 17J: 2014 (item 3.1.52).

PAH – Pressure Alarm High.

PLC – Programmable Logic Controller.

PI – Pressure Indicator (e.g., Manometer).


PIT – Pressure Indicator Transmitter. See Transmitter.

PSV – Pressure Safety Valve. In this Technical Specification, PSV is a synonym of pressure relief valve.

Range – The region within the measured values are (e.g.: Range: from 30mbar to 500mbar).

Safe area – Area (place) onboard where it is allowed and considered safe to exhaust the permeated gas from the Annulus (eventually with contaminants as CO₂ and H₂S) without risks for the health of the personnel, for the integrity of the installations (and of the FPU), for the security of the operations, and for the quality of the environment conditions. The concept is also valid for disposal of the liquid phase formed (condensate) inside the piping.

Shall – Denotes requirements which are mandatory and, therefore, which must be fulfilled.

	TECHNICAL SPECIFICATION	No. I-ET-3010.00-5529-812-PAZ-001	REV. H
			SHEET 4 of 19
	TITLE: ANNULUS PRESSURE MONITORING AND RELIEF SYSTEM		NP-1 SUB/ ES/ CIT

SN Curves – Means the curves of materials - showing stress range vs number of cycles - that are used by the manufacturer to define the fatigue life of dynamic risers submitted to cyclic loads.

Transmitter – The sensing element and the electronics that interprets and determines the measure (microprocessor based instrument).

VENDOR – A system or equipment Supplier, subcontracted by the CONTRACTOR/SELLER.

XV or X-V – Tag used for solenoid valves.

2. STANDARDS AND APPLICABLE DOCUMENTS

NOTE: Unless otherwise stated, the latest revision of the following documents shall be considered.

[Ref. 1] **API SPECIFICATION 17J** – Specification for Unbonded Flexible Pipe: 2014.

[Ref. 2] **ISO 13628-2** – Unbonded flexible pipe systems for subsea and marine applications: 2006.

[Ref. 3] **I-ET-004** – Safety Philosophy.

[Ref. 4] **IEC 60079** – Electrical apparatus for explosive gas atmospheres.

[Ref. 5] **CT-E&P-CORP-EEPIP-EISA-004-0/2014** – Internal report "*Análise de Riscos para Vent Contínuo de Gás Percolado em Risers*".

3. INTRODUCTION

This Technical Specification describes the components and establishes the requirements for the implementation, by the CONTRACTOR/SELLER, of the '*Annulus Pressure Monitoring and Relief System*'.

The requirements are only applied to FPU's that are connected to the top End fittings of the Flexible risers, at emerged positions (above the waterline, out of the splash-zone).


The main purposes of the '*Annulus Pressure Monitoring and Relief System*' are:

- To monitor and control, during Flexible riser operation, the pressure build up in the Annulus (keeping pressure values within the allowable and safe limits). Additionally, to monitor the pressure build up rates and relief intervals;
- To vent and exhaust the relieved Permeated gas into a Safe area onboard.

Pressure build up in the Annulus is mainly caused by gas permeation from the Flexible pipe bore.

Abnormalities may be related to the following Flexible riser failure mechanisms, for example:

- PSV blockage or plug in the Flexible riser gas venting system leading to: Permeated gas build up in the Annulus, rupture/ burst of riser Outer sheath and formation of a corrosive environment into the Annulus;
- Excessive deformation or degradation of the Internal pressure sheath material leading to: cracks in this layer (failure of the End fitting sealing system), leakage of medium into Annulus, rupture of Flexible riser Outer sheath and medium external leakage.

	TECHNICAL SPECIFICATION	No.	I-ET-3010.00-5529-812-PAZ-001	REV.	H
				SHEET	5 of 19
	TITLE: ANNULUS PRESSURE MONITORING AND RELIEF SYSTEM			NP-1	
				SUB/ ES/ CIT	

The basic configurations and the technical requirements presented in this Technical Specification are divided depending on the adopted type of '*Annulus Pressure Monitoring and Relief System*' among the following 3 (three) types:

- **Automatic Type** – See **item 4** of this Technical Specification;
- **Non-automatic or Manual Type** – See **item 5** of this Technical Specification;
- **Continuous Vented Type** – See **item 6** of this Technical Specification.

According to [Ref. 1 and Ref. 2], the Flexible riser gas-venting system is required to prevent excessive pressure build-up in Annulus. The maximum allowable pressure values in the riser Annulus depend on riser design premises (including the internal fluid specified parameters and composition data, as partial pressure of H₂S or CO₂ for example).

3.1 General Requirements

3.1.1- The type of the '*Annulus Pressure Monitoring and Relief System*' to be provided and implemented by the CONTRACTOR/SELLER shall be in accordance with the type defined in the FPU design basis issued by PETROBRAS.

3.1.2- CONTRACTOR/SELLER shall perform and document detailed engineering of the *Annulus Pressure Monitoring and Relief System*, including Risk assessment reports, Design reports, Technical Specifications of the components of the system (e.g. Piping, Headers, Sensors, Transmitters, Valves and complementary Equipment).


3.1.3- CONTRACTOR/SELLER shall perform and document detailed engineering of the *Annulus Pressure Monitoring and Relief System* based on representative Permeated gas data applicable to the Flexible riser structures to be connected to the FPU. In case the Permeated gas data are informed (by PETROBRAS) as "preliminary data", then CONTRACTOR/SELLER shall confirm that the proposed system to be implemented is safe and adequate to perform its function based on the definitive and final representative data. In this case, the confirmation shall be documented in the Project executive phase.

3.1.4- CONTRACTOR/SELLER shall determine the exact location of the Safe area onboard to exhaust the gas (for any type of the '*Annulus Pressure Monitoring and Relief System*' presented here), based on internationally recognized technical assumptions, premises, methodologies and criteria.

3.1.5- CONTRACTOR/SELLER shall perform a risk assessment according to [Ref. 3: I-ET-004 – Safety Philosophy] and submit (to be approved by PETROBRAS) a Risk Analysis Report to technically justify the determination of the Safe area location to exhaust the gas. The Risk Analysis Report shall be based on representative Permeated gas data (e.g. flow rates applicable to the riser structures to be connected to the FPU) and shall be in accordance with the FPU gas dispersion plan.

NOTE: In case it is expected - in the Project executive phase - to have the previously informed Permeated gas data revised, then a preliminary Risk Analysis Report (based on the available and preliminary Permeated gas data) may be submitted. In this case, in the Project executive phase, CONTRACTOR/SELLER shall confirm the location of the Safe area onboard to exhaust the Permeated gas, based on the final Permeated gas data (e.g. flow rates applicable to the Flexible riser structures to be connected to the FPU). See item 3.1.3

3.1.6- The basic configurations presented in this Technical Specification (depending on the adopted type of '*Annulus Pressure Monitoring and Relief System*') represents a conception design.

 PETROBRAS	TECHNICAL SPECIFICATION	No.	I-ET-3010.00-5529-812-PAZ-001	REV.	H
				SHEET	6 of 19
	TITLE: ANNULUS PRESSURE MONITORING AND RELIEF SYSTEM			NP-1	
				SUB/ ES/ CIT	

CONTRACTOR/SELLER shall detail the respective conception design and shall propose an executive design for final implementation after its approval by PETROBRAS.

3.1.7- The piping dimensions and all other component dimensions proposed throughout this document are the minimum required for the application. CONTRACTOR/SELLER shall confirm these dimensions (or propose an appropriated one higher or equal than the minimum proposed in this document) based on representative Permeated gas data (e.g. flow rate) applicable to the Flexible riser structures to be connected to the FPU. See item 3.1.3.

3.1.8- CONTRACTOR/SELLER shall be responsible for all component material selection, in order to guarantee compatibility with the process fluids (e.g. corrosion resistant) and external environment in contact. The material for all components in contact with the process fluids shall be AISI 316 stainless steel or better. CONTRACTOR/SELLER shall confirm the compatibility of the materials based on representative Permeated gas data (e.g. gas composition) applicable to the Flexible riser structures to be connected to the FPU. See item 3.1.3.

3.1.9- CONTRACTOR/SELLER shall provide all technical evidences of the adequacy of the selected material to the field conditions. If the CONTRACTOR/SELLER wishes to propose other materials to be used in these components, evidences of the proposed material adequacy shall be submitted to PETROBRAS for approval.

3.1.10- Representative Permeated gas data (e.g. flow rates, gas compositions) shall be referred in the detailed design documentation to be provided by CONTRACTOR/SELLER. See item 3.1.3.

3.1.11- The '*Annulus Pressure Monitoring and Relief System*' shall not be connected to the Flare. It shall be vented to the atmosphere in a Safe area.

3.1.12- Although the system will operate in the range of 0 barg to 5 barg, all components shall be rated to withstand to limits that consider safety factors/ margins (e.g. -1 barg to 10 barg).


3.1.13- As a general directive, all valves and equipment (e.g. pumps, PIT) shall be installed in accessible places (for in service inspection and maintenance), without scaffolding. In addition, connections to the Flexible riser top End fitting (and Annulus) shall be easily accessed.

3.1.14- CONTRACTOR/SELLER shall explain any divergences in its proposal regarding this specification, in the form of a list of deviations. The failure in submitting the deviations in a clear and distinguish way shall be considered as an affirmative of acceptance and full understanding of the content of this document.

3.1.15- It is the responsibility of the CONTRACTOR/SELLER to inform in writing to PETROBRAS, in the proposal, the existence of any conflict or divergence among the documents of this project.

3.1.16- The total or partial non attendance to this Technical Specification shall be explained by the CONTRACTOR/SELLER on a list of exceptions.

3.1.17- The concept of "safe area" herein presented (see item 1: "TERMS, ABBREVIATIONS AND DEFINITIONS") includes – besides the process of venting the permeated gas – the purge of the accumulated liquid inside the system (vapor of water that condensates throughout the piping on board, for example). Therefore, it is required that the final system configuration on board (to be detailed by CONTRACTOR/SELLER) also allows the safe disposal of the accumulated liquid inside the system and do not allow the liquid to return back to the riser annulus.

	TECHNICAL SPECIFICATION	No. I-ET-3010.00-5529-812-PAZ-001	REV. H
	SHEET 7 of 19		
	TITLE: ANNULUS PRESSURE MONITORING AND RELIEF SYSTEM		NP-1 SUB/ ES/ CIT

4. AUTOMATIC TYPE

4.1 Automatic Type Description

The Automatic Type integrates, into the FPU Supervisory system, both the automatic data acquisition process (performed automatically by Digital transmitters) and the automatic control process (performed automatically by a Solenoid valve actuation). The Automatic Type allows the Operator to configure alarms, to record historic series (and historic trends) and to have a tighter control of the Annulus conditions.

The Annulus shall be isolated by a Solenoid valve (X-V) resulting in monitored pressure build up due to the gas permeation. When the pressure reaches a pre-defined limit value, the Solenoid valve (X-V) opens, alleviating the Annulus pressure. Figure 4.1 shows the Annulus pressure behavior over time and the set points.




Figure 4.1 – Annulus Pressure behavior over time and set points

4.2 Automatic Type Configuration and Data List of Components

The Automatic Type configuration is shown by Figure 4.2 and consists of the components listed in Table 4.1. The component numbers mentioned on the Figure 4.2 are referred on Table 4.1.





Figure 4.2 – Basic Diagram for the Automatic Type

	TECHNICAL SPECIFICATION	No. I-ET-3010.00-5529-812-PAZ-001	REV. H
	SHEET 8 of 19		
	TITLE: ANNULUS PRESSURE MONITORING AND RELIEF SYSTEM		NP-1 SUB/ ES/ CIT

Item	Description of the Component	Specification (and Quantities)	Scope of supply
1	PSV Adapter	As per Flexible riser supplier	Flexible riser supplier
2	PSV	As per Flexible riser supplier (2)	Flexible riser supplier
3	Riser Access Connection	As per Flexible riser supplier (3)	Flexible riser supplier
4	Pressure Indicator Transmitter (PIT)	As per CONTRACTOR/SELLER	CONTRACTOR/SELLER
5	Manual Blocking Valve	As per CONTRACTOR/SELLER	CONTRACTOR/SELLER
6	Check Valve	As per CONTRACTOR/SELLER	CONTRACTOR/SELLER
7	Piping	As per CONTRACTOR/SELLER	CONTRACTOR/SELLER
8	Purger	As per CONTRACTOR/SELLER	CONTRACTOR/SELLER

Table 4.1 – Data List of Components – Automatic Type

4.3 Component Basic Requirements and Specifications - Automatic type

4.3.1- For the Automatic type, CONTRACTOR/SELLER shall complete the data list required in Table 4.1 above in order to specify and to determine the quantity of the components to be purchased (or to be provided) in this case.

4.3.2- The Solenoid valve (X-V) shall be of 3/8" and be certified to zone 1 IIA T3 (explosion proof type Ex-d), according to [Ref. 4: IEC 60079], with IP 56 or higher. The valve shall be a Fail Open (FO) type.

4.3.3- The Annulus gas discharge of each riser shall be collected by 1 (one) header with the minimum of 1" ID, as shown in Figure 4.2.

4.3.4- The technical specifications and quantities of the PSV Adapter (**item 1** of Figure 4.2 and Table 4.1) shall be informed and confirmed by the Flexible riser supplier.

4.3.5- The technical specifications and quantities of all PSVs (**item 2** of Figure 4.2 and Table 4.1) shall be informed and confirmed by the Flexible riser supplier (according to the specified technical requirements). According to [Ref. 1 and Ref. 2], at least, 2 (two) PSVs shall be used, as represented in Figure 4.2.


4.3.6- Each Flexible riser End fitting is normally supplied with 3 (three) connection ports for access to the Annulus (**item 3** of Figure 4.2 and Table 4.1). 1 (one) of these 3 (three) connections shall be used for the circuit with the Solenoid Valve (X-V) and the other 2 (two) ones shall be used for the circuit with the PSVs, as represented in Figure 4.2.

NOTE 1: The purpose of the set of 2 (two) PSVs (one as a backup of the other) is to act as a second safety layer in case of any failure of the 'Annulus Pressure Monitoring and Relief System'. In this case, 1 (one) of these 2 (two) PSVs will alleviate the Annulus pressure, discharging the Permeated gas to a Safe area through an alternative circuit, as per Figure 4.2.

NOTE 2: As stated before, connections to the Flexible riser top End fitting (and Annulus) shall be easily accessed (for in service maintenance), without scaffolding.

4.3.7- The Annulus pressure is sensed by a Pressure Transmitter (**item 4** of Figure 4.2 and Table 4.1) that shall be linked to a PLC. The PLC shall execute the required logic to actuate the Solenoid valve (X-V).

4.3.8- The Pressure Transmitter (**item 4** of Figure 4.2 and Table 4.1) shall be placed as close as possible to the Flexible riser top End fitting, in a location accessible to the workers, and shall have a local LCD display. This display will be used to monitor the pressure on site during the N₂ test (Nitrogen test).

 PETROBRAS	TECHNICAL SPECIFICATION	No.	I-ET-3010.00-5529-812-PAZ-001	REV.	H
				SHEET	9 of 19
	TITLE: ANNULUS PRESSURE MONITORING AND RELIEF SYSTEM			NP-1	
SUB/ ES/ CIT					

4.3.9- In addition, a Pressure Transmitter shall be installed near the outlet of the discharge header, to detect any clogging or plugging at this location (as represented by Figure 4.2).

4.3.10- Pressure values (and X-V status and X-V actuation indications) shall be available in the FPU supervisory system (and in the software used to acquire historical trends from the field instruments). Alarms that represent abnormalities (such as abnormal pressure build up in the Annulus, malfunction of the X-V or any clogging or plugging at the outlet of the discharge header) shall be set in the software of the FPU supervisory system.

4.3.11- The Pressure Transmitters shall be certified for zone 1 IIA T3, according to [Ref. 4: IEC 60079], with IP 56 or higher.

4.3.12- The Pressure Transmitters shall be provided calibrated, with its calibration reports.

4.3.13- The Pressure Transmitters shall attend the following minimum requirements:

- Range: 0 to 5 barg;
- Maximum Measurement Error: ± 0.1 bar.

4.3.14- The Manual Blocking Valves (**item 5** of Figure 4.2 and Table 4.1) shall be of 3/8" and shall be placed in a local with easy access to the workers. The valves shall be gas-tight.

4.3.15- 6 (six) Manual Blocking Valves (e.g. ball valve) are required for isolation of the circuit, as shown in Figure 4.2:

- **Normal Operation:** HV-1, HV-4 and HV-6 shall be opened and HV-2, HV-3 and HV-5 shall be closed;
- **Maintenance of the circuit:** HV-1 and HV-6 shall be closed;
- **Outer Sheath Nitrogen or Vacuum Test:** HV-1 and HV-2 shall be opened and HV-3, HV-4, HV-5 and HV-6 shall be closed;
- **By-Pass:** HV-5 shall be opened. This by-pass shall be used in case the X-V get stuck in the closed position.


4.3.16- The check valve (**item 6** of Figure 4.2 and Table 4.1) shall be of 3/8" and have a maximum cracking pressure of 0.2 bar.

4.3.17- The local piping (**item 7** of Figure 4.2 and Table 4.1) that connects the Annulus of each riser to the header shall be with the minimum of 3/8", as shown in Figure 4.2.

4.3.18- The local piping (**item 7** of Figure 4.2 and Table 4.1) shall be delivered by CONTRACTOR/SELLER with a 3/8" NPT female stainless steel end fitting to be connected to the flexible riser top end fitting (at the Annulus access port with a 3/8" NPT male stainless steel end fitting). The piping shall be delivered with plugs that are required to prevent entry of dirt and moisture in the piping. The piping shall be delivered clean (flushed) and dry. The connection of the riser Annulus to the venting system will be carried out by CONTRACTOR/SELLER, if not specified on the contrary.

NOTE: CONTRACTOR/SELLER shall consider having the local piping supported in the region of the connection point.

4.3.19- The Tee joint intended for either N₂ (Nitrogen test) or Vacuum test shall have a plugged 3/8" NPT thread termination and shall have an easy access for the workers.

	TECHNICAL SPECIFICATION	No. I-ET-3010.00-5529-812-PAZ-001	REV. H
	SHEET 10 of 19		
	TITLE: ANNULUS PRESSURE MONITORING AND RELIEF SYSTEM		NP-1 SUB/ ES/ CIT

4.3.20- A Purger (item 8 of Figure 4.2 and Table 4.1) shall be installed in the header, at the lowest position of the piping, for the disposal of the liquid phase formed (condensate). Since the fluid may contain contaminants such as H₂S and CO₂, it shall be discarded to an appropriate and Safe area.

4.3.21- The Purger (item 8 of Figure 4.2 and Table 4.1) is a mandatory component in the Automatic Type (as per figure 4.2). The piping adopted shall be designed in order to minimize the possibility of liquid accumulation and backpressure. As a general directive it is suggested to use a Purger with electronic actuation, certified to Zone 1 IIA T3 (explosion proof type Ex-d), according to [Ref. 4: IEC 60079], with IP 56 or higher. Alternative solutions for the purge may also be accepted if proven that they do not lead to pressure build-up and shall be submitted to Petrobras for approval.

5. NON-AUTOMATIC OR MANUAL TYPE

5.1 Manual Type Description

The Manual Type does not integrate, into the FPU Supervisory system, neither the data acquisition process (not performed automatically) nor the control one (performed manually).

5.2 Manual Type Configuration and Data List of Components

The Manual Type configuration is shown by Figure 5.1 and it consists of the components listed in Table 5.1. The component numbers mentioned on the Figure 5.1 are referred on Table 5.1.





Figure 5.1 – Basic Diagram for the Manual Annulus Monitoring and Relief System

Item	Description of the Component	Specification (and Quantities)	Scope of supply
1	PSV Adapter	As per Flexible riser supplier	Flexible riser supplier
2	PSV	As per Flexible riser supplier (2)	Flexible riser supplier
3	Riser Access Connection	As per Flexible riser supplier (3)	Flexible riser supplier
4	Pressure Indicator (PI)	As per CONTRACTOR/SELLER	CONTRACTOR/SELLER
5	Manual Blocking Valve	As per CONTRACTOR/SELLER	CONTRACTOR/SELLER
6	Check Valve	As per CONTRACTOR/SELLER	CONTRACTOR/SELLER
7	Piping	As per CONTRACTOR/SELLER	CONTRACTOR/SELLER
8	Purger	As per CONTRACTOR/SELLER	CONTRACTOR/SELLER

Table 5.1 – Data List of Components – Manual Type

 PETROBRAS	TECHNICAL SPECIFICATION	No.	I-ET-3010.00-5529-812-PAZ-001	REV.	H
				SHEET	11 of 19
	TITLE: ANNULUS PRESSURE MONITORING AND RELIEF SYSTEM			NP-1	
				SUB/ ES/ CIT	

5.3 Component Basic Requirements and Specifications - Manual type

5.3.1- For the Manual type, CONTRACTOR/SELLER shall complete the data list required in Table 5.1 above in order to specify and determine the quantity of the components to be purchased (or to be provided) in this case.

5.3.2- The Annulus gas discharge of each riser shall be collected by 1 (one) header with the minimum of 1" ID, as shown in Figure 5.1.

5.3.3- The technical specifications and quantities of the PSV Adapter (**item 1** of Figure 5.1 and Table 5.1) shall be informed and confirmed by the Flexible riser supplier.

5.3.4- The technical specifications and quantities of all PSVs (**item 2** of Figure 5.1 and Table 5.1) shall be informed and confirmed by the Flexible riser supplier (according to the specified technical requirements). According to [Ref. 1 and Ref. 2], at least, 2 (two) PSVs shall be used, as represented in Figure 5.1.

5.3.5- Each Flexible riser End fitting is normally supplied with 3 (three) connection ports for access to the Annulus (**item 3** of Figure 5.1 and Table 5.1). 1 (one) of these 3 (three) connections shall be used for the discharge circuit with the (HV-2) and the other 2 (two) ones shall be used for the circuit with the PSVs, as represented in Figure 5.1.

NOTE 1: The purpose of the set of 2 (two) PSVs (one as a backup of the other) is to act as a second safety layer in case of any failure of the 'Annulus Pressure Monitoring and Relief System'. In this case, 1 (one) of these 2 (two) PSVs will alleviate the Annulus pressure, discharging the Permeated gas to a Safe area through an alternative circuit, as per Figure 5.1.

NOTE 2: As stated before, connections to the Flexible riser top End fitting (and Annulus) shall be easily accessed (for in service maintenance), without scaffolding.

5.3.6- The Annulus pressure is sensed by a Pressure Indicator (item 4 of Figure 5.1 and Table 5.1). The Pressure Indicator shall be placed as close as possible to the Flexible riser top End fitting, in a location accessible to the workers, and shall have a local LCD display. This display will be used to monitor the pressure on site during the N₂ test (Nitrogen test).

5.3.7- In addition, a Pressure Indicator shall be installed near the outlet of the discharge header, to detect any clogging or plugging at this location (as represented by Figure 5.1).

5.3.8- The Pressure Indicators shall be certified for zone 1 IIA T3, according to [Ref. 4: IEC 60079], with IP 56 or higher.

5.3.9- The Pressure Indicators shall be provided calibrated, with its calibration reports.


5.3.10- The Pressure Indicators shall attend the following minimum requirements:

- Range: 0 to 5 barg;
- Maximum Measurement Error: ± 0.1 bar.

5.3.11- The Manual Blocking Valves (**item 5** of Figure 5.1 and Table 5.1) shall be of 3/8" and shall be placed in a local with easy access to the workers. The valves shall be gas-tight.

5.3.12- 4 (Four) Manual Blocking Valves (e.g. ball valve) are required for isolation of the circuit, as shown in Figure 5.1:

- **Normal Operation:** HV-4 shall be opened, HV-1, HV-2 and HV-3 shall be closed;

 PETROBRAS	TECHNICAL SPECIFICATION	No.	I-ET-3010.00-5529-812-PAZ-001	REV.	H
				SHEET	12 of 19
	TITLE: ANNULUS PRESSURE MONITORING AND RELIEF SYSTEM			NP-1	
SUB/ ES/ CIT					

- **Maintenance of the circuit:** HV-2 and HV-3 shall be closed (it is required to relieve the pressure before by HV-1);
- **Outer Sheath Nitrogen or Vacuum Test:** HV-1 shall be opened and HV-2, HV-3 and HV-4 shall be closed.
- **Manual Pressure Relief:** HV-2 shall be opened.

5.3.13- The check valve (**item 6** of Figure 5.1 and Table 5.1) shall be of 3/8" and have a maximum set pressure of 0.2 bar.

5.3.14- The local piping (**item 7** of Figure 5.1 and Table 5.1) that connects the Annulus of each riser to the header shall be with the minimum of 3/8", as shown in Figure 5.1.

5.3.15- The local piping (**item 7** of Figure 5.1 and Table 5.1) shall be delivered by CONTRACTOR/SELLER with a 3/8" NPT female stainless steel end fitting to be connected to the flexible riser top end fitting (at the Annulus access port with a 3/8" NPT male stainless steel end fitting). The piping shall be delivered with plugs that are required to prevent entry of dirt and moisture in the piping. The piping shall be delivered clean (flushed) and dry. The connection of the riser Annulus to the venting system will be carried out by CONTRACTOR/SELLER, if not specified on the contrary.

NOTE: CONTRACTOR/SELLER shall consider having the local piping supported in the region of the connection point.

5.3.16- The Tee joint intended for either N₂ (Nitrogen test) or Vacuum test shall have a plugged 3/8" NPT thread termination and shall have an easy access for the workers.

5.3.17- A Purger (**item 8** of Figure 5.1 and Table 5.1) shall be installed in the header, at the lowest position of the piping, for the disposal of the liquid phase formed (condensate). Since the fluid may contain contaminants such as H₂S and CO₂, it shall be discarded to an appropriate and Safe area.

5.3.18- The Purger (**item 8** of Figure 5.1 and Table 5.1) is a mandatory component in the Manual Type (as per figure 5.1). The piping adopted shall be designed in order to minimize the possibility of liquid accumulation and backpressure. As a general directive it is suggested to use a Purger with electronic actuation, certified to Zone 1 IIA T3 (explosion proof type Ex-d), according to [Ref. 4: IEC 60079], with IP 56 or higher. Alternative solutions for the purge may also be accepted if proven that they do not lead to pressure build-up and shall be submitted to Petrobras for approval.


6. CONTINUOUS VENTED TYPE

The Continuous Vented Type is characterized by the pressure monitoring in the Annulus that is continuously kept in contact with the external environment at an atmosphere pressure.

As per cited in item 3 (INTRODUCTION), if the dimensioning and material selection of the Flexible riser structure are based on riser Annulus continuously vented to the atmosphere, then the Continuous Vented Type shall be used instead of any other type (Automatic or Manual one).

The main purpose of adopting the Continuous Vented Type is to keep the *Annulus* pressure as low as possible. Normally, this type is adopted for sour service riser applications (or risers that flow acid gas). The Continuous Vented Type configurations and requirements are classified according to the following 2 different options:

6.1- Continuous Vented Type (with Header);

	TECHNICAL SPECIFICATION	No. I-ET-3010.00-5529-812-PAZ-001	REV. H
			SHEET 13 of 19
	TITLE: ANNULUS PRESSURE MONITORING AND RELIEF SYSTEM		NP-1 SUB/ ES/ CIT

6.2- Local Continuous Vented Type.

6.1.1 Continuous Vented Type (with Header) – Configuration and Data List of Components

This option is applied on FPU with Flexible riser top End fittings located inside a confined place (e.g. Turret of the FPU).

The configuration of the **Continuous Vented Type (with Header)** is shown by Figure 6.1 and it consists of the components listed in Table 6.1. The component numbers mentioned on the Figure 6.1 are referred on Table 6.1.




Figure 6.1 – Basic Diagram for the Continuous Vented Type (with Header)


Item	Description of the Component	Specification (and Quantities)	Scope of supply
1	Riser Access Connection	As per Flexible riser supplier (3)	Flexible riser supplier
2	Pressure Indicator Transmitter (PIT)	As per CONTRACTOR/SELLER	CONTRACTOR/SELLER
3	Manual Blocking Valve	As per CONTRACTOR/SELLER	CONTRACTOR/SELLER
4	Check Valve	As per CONTRACTOR/SELLER	CONTRACTOR/SELLER
5	Piping	As per CONTRACTOR/SELLER	CONTRACTOR/SELLER
6	Vacuum Pump	As per CONTRACTOR/SELLER	CONTRACTOR/SELLER

Table 6.1 – Data List of Components – Continuous Vented Type (with Header)

6.1.2 Continuous Vented Type (with Header) – Component Basic Requirements and Specifications

6.1.2.1- For the Continuous Vented Type (with Header), CONTRACTOR/SELLER shall complete the data list required in Table 6.1 above in order to specify and determine the quantity of the components to be purchased (or to be provided) in this case.

6.1.2.2- For this type, the Annulus shall be continuously exhausted using a pumping system that generates a negative pressure so to assure that all fluids gathered from each riser and conveyed to the header to be vented, as represented in Figure 6.1.

<div> PETROBRAS</div>	TECHNICAL SPECIFICATION	No.	I-ET-3010.00-5529-812-PAZ-001	REV.	H
				SHEET	14 of 19
	TITLE: ANNULUS PRESSURE MONITORING AND RELIEF SYSTEM			NP-1	
				SUB/ ES/ CIT	

NOTE: The **Continuous Vented Type** shall not allow the build-up of backpressure in the system. Therefore, the devices annexed to the system (e.g., check valves) shall be specified and configured to minimize the pressure build-up.

6.1.2.3- The Annulus gas discharge of each riser shall be collected by 1 (one) header with the minimum of 1" ID, as shown in Figure 6.1. The header will be connected a vertical piping that will exhaust all gathered fluids from the header to a Safe area.

6.1.2.4- Each Flexible riser End fitting is normally supplied with 3 (three) connection ports for access to the Annulus (**item 1** of Figure 6.1 and Table 6.1). As stated before, connections to the Flexible riser top End fitting (and Annulus) shall be easily accessed (for in service maintenance), without scaffolding.

6.1.2.5- The Annulus pressure is sensed by a Pressure Transmitter (**item 2** of Figure 6.1 and Table 6.1) that shall be linked to a PLC.

6.1.2.6- The Pressure Transmitter (**item 2** of Figure 6.1 and Table 6.1) shall be placed as close as possible to the Flexible riser top End fitting, in a location accessible to the workers, and shall have a local LCD display. This display will be used to monitor the pressure on site during the N₂ test (Nitrogen test).

6.1.2.7- In addition, a Pressure Transmitter shall be installed near the outlet of the discharge header, to detect any clogging or plugging at this location (as represented by Figure 6.1).

6.1.2.8- Pressure values shall be available in the FPU supervisory system (and in the software used to acquire historical trends from the field instruments). Alarms that represent abnormalities (such as abnormal pressure build up in the Annulus or any clogging or plugging at the outlet of the discharge header) shall be set in the software of the FPU supervisory system.

6.1.2.9- The Pressure Transmitters shall be certified for zone 1 IIA T3, according to [Ref. 4: IEC 60079], with IP 56 or higher.

6.1.2.10- The Pressure Transmitters shall be provided calibrated, with its calibration reports.

6.1.2.11- The Pressure Transmitters shall attend the following minimum requirements:


- Range: -1 to 5 barg;
- Maximum Measurement Error: ± 0.1 bar.

6.1.2.12- The Manual Blocking Valves (**item 3** of Figure 6.1 and Table 6.1) shall be of 3/8" and shall be placed in a local with easy access to the workers. The valves shall be gas-tight.

6.1.2.13- The HV-2 physical location (position) shall be determined by the CONTRACTOR/SELLER based on Risk Analysis evaluation considering the following scenario: In case of pressure alarm, the valve HV-2 shall be opened in order to reduce the pressure on the PIT to protect the Flexible riser Outer sheath. If the pressure is not reduced the valve HV-1 shall be closed and the pipes shall be cleaned.

6.1.2.14- 5 (five) manual blocking valves (e.g.: ball valve) are required for isolation of the circuit:

- **Normal Operation:** HV-1, HV-4 and HV-5 shall be opened and HV-2 and HV-3 shall be closed;
- **Maintenance of the circuit:** HV-1 and HV-5 shall be closed;

 PETROBRAS	TECHNICAL SPECIFICATION	No.	I-ET-3010.00-5529-812-PAZ-001	REV.	H
				SHEET	15 of 19
	TITLE: ANNULUS PRESSURE MONITORING AND RELIEF SYSTEM			NP-1	
				SUB/ ES/ CIT	

- **Outer Sheath Nitrogen or Vacuum Test:** HV-1 and HV-2 shall be opened and HV-4 and HV-5 shall be closed.

6.1.2.15- The following blocking valves shall be lock open: HV-1, HV-4 and HV-5.

6.1.2.16- The check valve (**item 4** of Figure 6.1 and Table 6.1) shall be of 3/8" and have a maximum set pressure of 0.2 bar.

6.1.2.17- The local piping (**item 5** of Figure 6.1 and Table 6.1) that connects the Annulus of each riser to the header shall be with the minimum of 3/8", as shown in Figure 6.1.

NOTE: Piping will individually connect each Flexible riser End fitting (and its Annulus) to a header that will receive all fluids gathered from the risers.

6.1.2.18- The local piping (**item 5** of Figure 6.1 and Table 6.1) shall be delivered by CONTRACTOR/SELLER with a 3/8" NPT female stainless steel end fitting to be connected to the flexible riser top end fitting (at the Annulus access port with a 3/8" NPT male stainless steel end fitting). The piping shall be delivered with plugs that are required to prevent entry of dirt and moisture in the piping. The piping shall be delivered clean (flushed) and dry. The connection of the riser Annulus to the venting system will be carried out by CONTRACTOR/SELLER, if not specified on the contrary.


NOTE: CONTRACTOR/SELLER shall consider having the local piping supported in the region of the connection point.

6.1.2.19- The Tee joint intended for either N₂ (Nitrogen test) or Vacuum test shall have a plugged 3/8" NPT thread termination and shall have an easy access for the workers.

6.1.2.20- The local pumping system (**item 6** of Figure 6.1 and Table 6.1) shall fulfill the following requirements:

- a) This local system shall prevent the ingress of air from the external environment at the level of 5 ppb of O₂ maximum, which is compatible with the criteria for oxygen allowed in the flexible riser Annulus and for SN Curves used in riser design for wet and flooded Annulus conditions.
- b) At the upper deck level, the pumping system will provide an appropriate negative pressure to the header and lower piping so to assure the exhausting of all gathered fluids from the Annulus of all the Flexible risers.
- c) The pumping system shall consist of at least two pumps (1 spare). Whenever the pump in continuous operation stops, the spare pumps shall automatically start operation. The system shall have a manifold with check valves and flanged connections that allows the easy retrieval of the damaged pump for maintenance without the stoppage of the exhausting of fluids from the respective Annulus of all the Flexible risers.
- d) The pumps shall have high MTTF and MTBF (above 5 years).
- e) The pump must operate continuously with a negative pressure of 0.2 bar at the flexible riser end fitting considering the head loss from all the system (piping, valves, etc).

NOTE: As stated before, all valves and equipment (e.g., pumps) shall be installed in accessible places (for in service inspection and maintenance), without scaffolding.

	TECHNICAL SPECIFICATION	No. I-ET-3010.00-5529-812-PAZ-001	REV. H
	SHEET 16 of 19		
	TITLE: ANNULUS PRESSURE MONITORING AND RELIEF SYSTEM		NP-1 SUB/ ES/ CIT

6.2.1 Local Continuous Vented Type – Configuration and Data List of Components

This option is applied on FPU with Flexible riser top End fittings located in vented places (e.g. riser balcony of a Spread Mooring FPU). In this case, the Annulus shall be continuously vented to the atmosphere.

The configuration of the **Local Continuous Vented Type** is shown by Figure 6.2 and it consists of the components listed in Table 6.2. The component numbers mentioned on the Figure 6.2 are referred on Table 6.2.




Figure 6.2 – Basic Diagram for the Local Continuous Vented Type


Item	Description of the Component	Specification (and Quantities)	Scope of supply
1	Riser Access Connection	As per Flexible riser supplier (3)	Flexible riser supplier
2	Pressure Indicator Transmitter (PIT)	As per CONTRACTOR/SELLER	CONTRACTOR/SELLER
3	Manual Blocking Valve	As per CONTRACTOR/SELLER	CONTRACTOR/SELLER
4	Check Valve	As per CONTRACTOR/SELLER	CONTRACTOR/SELLER
5	Piping	As per CONTRACTOR/SELLER	CONTRACTOR/SELLER
6	PSV	As per Flexible riser supplier (1)	Flexible riser supplier

Table 6.2 – Data List of Components – Local Continuous Vented Type

6.2.2 Local Continuous Vented Type – Component Basic Requirements and Specifications

6.2.2.1- For the **Local Continuous Vented Type**, CONTRACTOR/SELLER shall complete the data list required in Table 6.2 above in order to specify and determine the quantity of the components to be purchased (or to be provided) in this case.

6.2.2.2- For this type, the Annulus shall be continuously vented by an individual vent line, as represented in Figure 6.2. The discharge shall be over sea and at least 800 millimeters descendent from the riser balcony. As per item 3.1.4 above, CONTRACTOR/SELLER shall determine the exact location of the Safe area onboard to exhaust the gas. For the Local Continuous Vented Type, CONTRACTOR/SELLER shall determine the final location of the discharge point over the sea.

 PETROBRAS	TECHNICAL SPECIFICATION	No.	I-ET-3010.00-5529-812-PAZ-001	REV.	H
				SHEET	17 of 19
	TITLE: ANNULUS PRESSURE MONITORING AND RELIEF SYSTEM			NP-1	
SUB/ ES/ CIT					

CONTRACTOR/SELLER shall confirm that this location is a Safe area, based on a gas-dispersion study and, also, on a risk analysis.

6.2.2.3- CONTRACTOR/SELLER shall be responsible to follow all the applicable safety rules to confirm the location of the Safe area (point of discharge of the Annulus gas of each riser).

6.2.2.4- This type (option) shall prevent the ingress of air from the external environment at the level of 5 ppb of O₂ maximum, which is compatible with the criteria for oxygen allowed in the Flexible riser Annulus and for SN Curves used in riser design for wet and flooded Annulus conditions.

6.2.2.5- Each Flexible riser End fitting is normally supplied with 3 (three) connection ports for access to the Annulus (**item 1** of Figure 6.2 and Table 6.2). As stated before, connections to the Flexible riser top End fitting (and Annulus) shall be easily accessed (for in service maintenance), without scaffolding.

6.2.2.6- The Annulus pressure is sensed by a Pressure Transmitter (**item 2** of Figure 6.2 and Table 6.2) that shall be linked to a PLC.

6.2.2.7- The Pressure Transmitter (**item 2** of Figure 6.2 and Table 6.2) shall be placed as close as possible to the Flexible riser top End fitting, in a location accessible to the workers, and shall have a local LCD display. This display will be used to monitor the pressure on site during the N₂ test (Nitrogen test).

6.2.2.8- Pressure values shall be available in the FPU supervisory system and (and in the software used to acquire historical trends from the field instruments). Alarms that represent abnormalities (such as abnormal pressure build up in the Annulus) shall be set in the software of the FPU supervisory system.

6.2.2.9- The Pressure Transmitters shall be certified for zone 1 IIA T3, according to [Ref. 4: IEC 60079], with IP 56 or higher.

6.2.2.10- The Pressure Transmitters shall be provided calibrated, with its calibration reports.

6.2.2.11- The Pressure Transmitters shall attend the following minimum requirements:

- Range: 0 to 5 barg;
- Maximum Measurement Error: ± 0.1 bar.


6.2.2.12- The Manual Blocking Valves (**item 3** of Figure 6.2 and Table 6.2) shall be of 3/8" and shall be placed in a local with easy access to the workers. The valves shall be gas-tight.

6.2.2.13- In case of pressure alarm, the valve HV-2 shall be opened in order to reduce the pressure on the PIT to protect the Flexible riser Outer sheath. If the pressure is not reduced the valve HV-1 shall be closed, and the pipes shall be cleaned.

6.2.2.14- 5 (five) manual blocking valves (e.g.: ball valve) are required for isolation of the circuit:

- **Normal Operation:** HV-1, HV-4 and HV-5 shall be opened and HV-2 and HV-3 shall be closed;
- **Maintenance of the circuit:** HV-1 shall be closed;
- **Outer sheath Nitrogen or Vacuum Test:** HV-1 and HV-2 shall be opened and HV-3, HV-4 and HV-5 shall be closed.

6.2.2.15- The check valve (**item 4** of Figure 6.2 and Table 6.2) shall be of 3/8" and have a maximum set pressure of 0.2 bar.

	TECHNICAL SPECIFICATION	No. I-ET-3010.00-5529-812-PAZ-001	REV. H
			SHEET 18 of 19
	TITLE: ANNULUS PRESSURE MONITORING AND RELIEF SYSTEM		NP-1 SUB/ ES/ CIT

6.2.2.16- The local piping (**item 5** of Figure 6.2 and Table 6.2) that connects the Annulus of each riser to the atmosphere shall be with the minimum of 3/8", as shown in Figure 6.2.

6.2.2.17- The local piping (**item 5** of Figure 6.2 and Table 6.2) shall be delivered by CONTRACTOR/SELLER with a 3/8" NPT female stainless steel end fitting to be connected to the flexible riser top end fitting (at the Annulus access port with a 3/8" NPT male stainless steel end fitting). The piping shall be delivered with plugs that are required to prevent entry of dirt and moisture in the piping. The piping shall be delivered clean (flushed) and dry. The connection of the riser Annulus to the venting system will be carried out by CONTRACTOR/SELLER, if not specified on the contrary.

NOTE: CONTRACTOR/SELLER shall consider having the local piping supported in the region of the connection point.

6.2.2.18- The Tee joint intended for either N₂ (Nitrogen test) or Vacuum test shall have a plugged 3/8" NPT thread termination and shall have an easy access for the workers.

6.2.2.19- 1 (one) PSV (**item 6** of Figure 6.2 and Table 6.2) shall be kept on the top End fitting as shown in Figure 6.2 (The PSV shall be supplied by the Flexible riser manufacturer).

6.2.2.20- All components (valves, equipment, and connections) shall be installed in accessible places (with easy access for in service maintenance), without scaffolding.


6.2.2.21- The configuration proposed by Figure 6.2 does not prevent the relief of permeated gas in the riser deck and riser balcony. For example, the gas relief can occur during: (a) The riser operation phase, in case the remaining PSV (**item 6** in Figure 6.2. and Table 6.2) opens after an eventual blockage of the system; and during: (b) The execution of in-service riser inspection, testing and maintenance activities (e.g., when replacing the cited remaining PSV if necessary). Therefore, CONTRACTOR/SELLER shall evaluate the safety of the personnel involved in these activities (i.e., in-service riser operation, testing, inspection, and maintenance) and safety equipment shall be properly handled to ensure the compliance of the personnel safety requirements applicable to the scenario of exposure to the permeated gas in the riser deck and riser balcony. Special attention shall be paid to the safety of the riser inspection climbing teams (beyond the limit of the riser balcony), considering the same scenario (i.e., personnel exposure to the vented permeated gas). It is recommended that the personnel directly involved in this inspection activity shall wear a mask that filters the toxic gases. Also, specific guidance - regarding the handling of the vent piping - shall also be given (to the personnel directly involved in this inspection activity) to avoid directing its output towards the person's face.

7. SYSTEM SET POINTS

7.1- The following system set points shall be used:

- Open X-V (Automatic System): 1.0 barg;
- Close X-V (Automatic System): 0.5 barg;
- PAH: 1.5 barg (Automatic System – see Figure 4.1);
- PAH (Manual System): 1.0 barg;
- PAH (for both "*Continuous Vented System with Header*" and "*Local Continuous Vented System*"): 1.0 barg.

7.2- These set points shall be software configurable by PETROBRAS.

	TECHNICAL SPECIFICATION	No.	I-ET-3010.00-5529-812-PAZ-001	REV.	H
				SHEET	19 of 19
	TITLE: ANNULUS PRESSURE MONITORING AND RELIEF SYSTEM			NP-1	
				SUB/ ES/ CIT	

8. SYSTEM ACCEPTANCE TEST

8.1- In order to demonstrate the system integrity and its functionality, acceptance tests shall be conducted by the CONTRACTOR/SELLER or VENDOR, witnessed by PETROBRAS. The acceptance test shall verify the (i) integrity of all piping (as per design code selected by the CONTRACTOR/SELLER) and, also, the functionality of each component (e.g. check valve, purger, pump, and relief system).

8.2- The CONTRACTOR/SELLER or VENDOR shall elaborate a test procedure, to be approved by PETROBRAS. PETROBRAS shall be informed with at least one month of antecedence the local and date of the test.

9. DOCUMENTATION

9.1- At least, the following documents shall be submitted by CONTRACTOR/SELLER:

- Datasheet of all components;
- System Component List, with part numbers;
- Welding Procedure Specifications (WPS) and welding procedure qualification records (WPQR);
- Welders qualification records;
- Inspection plan for piping welding including DNE;
- Acceptance Test Procedure;
- Pressure transmitters calibration reports;
- Mechanical drawings;
- List of Exceptions or Deviations to this Technical Specification;
- PLC codes (logics);
- Table relating the TAG of each pressure transmitter to its serial number and its riser;
- Risk Analysis Report (see item 3.1.5).